

**GOVERNMENT OF MEGHALAYA
OFFICE OF THE CHIEF ENGINEER, PHE,
MEGHALAYA:: SHILLONG**

No.CE/PHE/JJM/SPMU/WQ-55/2023-2024/27

Dated Shillong the, 23/02/2024

Corrigendum & Response to Bid Query


Tender Ref No : No.CE/PHE/JJM/SPMU/WQ-55/2023-2024/17
Date : 19/01/2024
Subject : Supply, Installation and Maintenance of Electro Chlorinator System in Meghalaya

The provision of the Tender document for *Supply, Installation and Maintenance of Electro Chlorinator System in Meghalaya* are being amended/revised through corrigendum attached herewith at **Annexure-I**. These documents will form part of the Tender document and subsequently signed contract documents.

Additionally, the response to the Pre-Bid Query/Request/Suggestion attached in **Annexure-II** (including modification in terms of tender clause) will form an integral part of the tender document & subsequently the signed tender agreement.

The above mentioned Tender has also been further extended as given below.


- 1.Last date and time for submission : 04.03.2024 at 13.00 Hrs.
- 2.Bid opening date and time : 04.03.2024 at 15.00 Hrs.


Chief Engineer, PHE
Meghalaya, Shillong

Memo No. CE/PHE/JJM/SPMU/WQ-55/2023-2024/27-A
Copy to:-


Dated Shillong the, 23/02/2024

1. The Director of Information and Public Relation, Meghalaya, Shillong for information and necessary action. The Corrigendum & Response to Bid Query may be published on one issue of 3 (Three) leading Local Daily preferably in 1 (One) English, 1 (One) Khasi & 1 (One) Garo Daily. 4 (Four) Copies of the Notice are enclosed herewith.
2. The Director of Printing & Stationery, Meghalaya, Shillong for favour of information, with a request to arrange publication of the same in the next issue of the Meghalaya Gazette.
3. The State Informatics Officer, NIC for information with a request for hoisting the Corrigendum & Response to Bid Query in the Meghalaya website.
4. All the Addl. Chief Engineers, PHE for publicity.
5. All the Superintending Engineers, (PHE) for publicity.
6. All the Executive Engineers (PHE) for publicity.
7. Notice Board.


Chief Engineer, PHE
Meghalaya, Shillong

Annexure-I


Sl. No	Ref Page No.	Clause No.	Relevant Clause	Amended/Revised Clause
1.	1	3	Value of non-refundable Court Fee Stamp- ₹ 5,000.00 purchase in Meghalaya.	Non- Refundable Court fee stamp worth ₹ 5000 (Five thousand) purchased from any region in India.
2.	1-2	6	The bid must be accompanied by a bid security of the amount specified below valid for a minimum period of 12 months, in a form of call deposit /fixed Deposit in a separate sealed envelope without which the bid shall be returned to Bidder unopened.	EMD/Bid Security Beneficiary- need to be paid in the favour of “The Chief Engineer, PHE, Meghalaya, Shillong” payable & drawn at SBI Bank.
3.	3	14-A , Point (V)	Proposal application with Joint Venture/consortiums will not be allowed.	Joint Ventures are allowed preferably only with local contractors.
4.	3	14-A , Point (VIII)	The Manufacturer must be a manufacturer of Electro chlorinator System duly inspected and tested and having BIS certification mark. For minimum last 3 years.	This clause will not be enforced.
5.	6	21-5	Dosing tank of suitable capacity made from PVC/FRP.	Dosing tank of suitable capacity made from PVC/FRP/HDPE.


Chief Engineer, PHE
Meghalaya, Shillong
23/7/24

Annexure-II

Sl. No	Reference(s)/ Section(s)/ Page No.	Query	Request for Consideration	Response
1	Clause 14-A (V), Page-3	Proposal application with Joint Venture / consortiums will not be allowed.	It will not be possible for an organization from outside of Meghalaya to participate & to provide better service without making any consortium with local contractors so kindly allow the consortium.	Refer Corrigendum
2	Clause 14-A (VIII), Page-3	The Manufacturer must be a manufacturer of Electro chlorinator System duly inspected and tested and having BIS certification mark. For minimum last 3 years.	<p>1. BIS Certificate is not applicable for electro chlorinator. Kindly remove the same.</p> <p>2. The Manufacturer shall provide product constructed by lab of Government of India i.e Council of Scientific & Industrial Research (CSIR) or equivalent with three Plant/Unit test certificate.</p> <p>3. There is no BIS certification mark for Electro-chlorination. Hence, we request that this should be removed</p> <p>4. BIS certification-Not applicable (NO BIS certification available for Electro-chlorinator)</p> <p>5. There is no BIS certification required for this product in India</p>	Refer Corrigendum
3	Clause 5, Page-1	Last date of submission of bid and opening of bid	<p>1. Kindly extend the time of submission up to 24.02.2024 so that we can prepare the required documents.</p> <p>2. We have already opted original Tender documents from your office but we are unable to submit hard copy of the tender documents personally within given time frame since our Head office is situated in Nagpur, Maharashtra & Therefore requested for extension of time at least for 15 days.</p>	Refer Corrigendum
4	Clause 6, Page 1 & 2	The bid must be accompanied by a bid security of the amount specified below valid for a minimum period of 12 months, in a form of call deposit /fixed Deposit in a separate sealed envelope without which the bid shall be returned to Bidder unopened.	As per the guidelines of Tender, Bid Security (EMD) OF Rs. 5,00,00.00/- needs to submit in the form of FDR but beneficiary of FDR not mentioned for the same. (Validity period of FDR 12 months) & therefore you are requested to provide bank details in shillong Meghalaya.	Refer Corrigendum
5	Clause 3, Page-1	Value of non-refundable Court Fee Stamp- ₹ 5,000.00 purchase in Meghalaya	We are unable to make payment online towards Non-Refundable stamp duty @ 5,000/- for court fee, hence it is requested to guide or suggest some other offline option for the same.	Refer Corrigendum
6	Clause 14-B (IV), Page -4	The Bidder shall fill on BOQ, the prices for the Works in conformity with the Bidding Documents, both in figures and words.	Please confirm if it is needed to fill original tender documents of BOQ by hand for electro chlorinator-batch system, continuous system, solar power supply)	Yes

7	Clause 14-A (I), Page -3	Manufacturing Companies/ Brand Owner Companies or any legal entity having 10 years of Age as on (Nov 2023) and above i.e. Date of registration must be on or before (Nov 2013).	Manufacturing Companies having 3 years of age as on (Nov23) , Date of registration before (Nov 2019)	RFP Terms and Conditions prevail
8	Clause 14-A (II), Page -3	Manufacturing Companies/ Brand Owner Companies should have satisfactorily complete similar nature of work of value: •If single agreement, not less than INR 40 Lakhs. •If two agreements or more, not less than INR 90 Lakhs	Manufacturing Companies should have satisfactorily completed similar nature of work (quantity of supply minimum 100 pieces in any one year)	
9	Clause 14-A (III), Page -3	The firm should have a minimum annual turnover* of Rs.5 Crore in each financial year from 2020 to 2023.	The manufacturing firm should have had a minimum cumulative turnover of 3 cr in the last 3 years	
10	Clause 14-A (IV), Page -3	The Manufacturing Companies/Brand Owner Companies must have a minimum of 3 years of experience* between FY 20-21 to FY 22-23 in implementation of Electro chlorination in water supply schemes of any State Government / central government organizations / PSU in India.	The manufacturing companies should have a minimum 3 years of experience in implementation of Electro chlorination in water supply schemes	
11	Clause 14-A (VI), Page -3	The Manufacturing Companies/Brand Owner Companies must have Valid ISO certification (ISO 9001:2015) & (ISO 14001:2015) from competent authority of Govt, of India.	1.ISO Cert-Not Applicable 2. As an MSME we are not holding ISO14001 and it is not required for the supply installation manufacturing and maintenance of Electro chlorination system. Please clarify	
12	Clause 14-B (III), Page -3	All duties, taxes and other levies payable by the contractor under the contract shall be included in the total price.	On page 3 you mentioned that the prices to be quoted should be inclusive of GST , while on page 6 it has been mentioned that prices are excluding GST and 0.4% inspections charges by TPI	
13	Clause 21 (5), Page -6	Dosing tank of suitable capacity made from PVC/FRP.	Dosing tanks or hypo chloride storage tanks are generally, are of HDPE as a standard. We had been supplying HDPE Tanks to various States for Several Years now. We request that PVC and HDPE both be allowed	Refer Corrigendum


 Chief Engineer, PHE
 Meghalaya, Shillong